

## **ADDENDUM NO. 2**

**June 2, 2008**

### **ELIMINATION OF THE SCHNEIDER PUMP STATION NORTH RIDGEVILLE, OHIO**

1. On Sheet FP-2 of the Bid Book, revise the description of Bid Item 14 from “Plug and Grout Existing Force Main” to “Plug and Abandon Existing Force Main”.

Explanation: The existing force main is to be plugged at each end of the force main at the locations shown on the plans using cast iron or ductile iron plugs. The removal of the force main at the eastern end is still included as previously described. The grouting portion of the Bid Item is being non-performed.

2. On Sheet FP-3 of the Bid Book, revise the dollar amount in Bid item 21 of the “Work Allowance (As Directed By The Engineer)” from \$65,000.00 to \$25,000.00.
3. The change in the dollar amount in Bid Item 21 does not change the Engineer’s Estimate of \$165,580.00.

**END OF ADDENDUM**